

Summary of Testing Results
South Sioux City, NE

Summary of Results from November 5, 2016 through November 25, 2016:

Sampling Point	Location	Total Sulfides (mg/L)			H2S (ppm)					
		Average	Min	Max	Instrument START Date/Time	Instrument END Date/Time	Average	Min	Max	Time of Max Measurement
1	Dakota Avenue/BPI Drive	0.08	0.01	1.00	11/9/2016, 4:00 PM	11/22/2016, 9:10 AM	1.2	0	50	11/20/2016, 9:50 PM
2	G St. and E. 39th St. EAST of Plug	0.23	0.05	1.45	11/9/2016, 3:15 PM	11/26/2016, 10:10 AM	5.1	0	63	11/13/2016, 2:45 PM
3	Bennet Lift Station	0.45	0.05	2.10	11/9/2016, 3:40 PM	11/16/2016, 8:06 AM	8.8	0	67	11/9/2016, 11:00 PM
4	G St. and E. 39th St. WEST of Plug	2.02	0.05	15.80	11/9/2016, 3:00 PM	11/26/2016, 10:30 AM	16.6	0	1330	11/16/2016, 7:44 PM
5	G St. and Apache Drive	0.40	0.05	2.20	11/18/2016, 4:00 PM	11/26/2016, 10:20 AM	8.0	0	747	11/16/2016, 7:22 PM
6	E. 39th St. and Dakota Ave	0.75	0.05	6.70	11/17/2016, 11:15 AM	11/26/2016, 10:40 AM	13.5	0	103	11/17/2016, 2:22 PM
7	Dakota Ave. South (in front of Hotel)	0.49	0.10	3.60	11/16/2016, 3:45 PM	11/26/2016, 10:50 AM	3.9	0	418	11/16/2016, 9:22 PM